



Technical Requirements Summary

New Residential, Single-Family Detached Homes



HURRICANE



FORTIFIED is a program of the Insurance Institute for Business & Home Safety



INTRODUCTION

The Insurance Institute for Business & Home Safety's FORTIFIED Home™: Hurricane Standard helps homeowners in coastal areas strengthen their houses against these powerful storms. Incorporating the FORTIFIED Standard when repairing, rebuilding or renovating your single-family home will transform your house into a more a resilient and durable property.

The FORTIFIED program offers flexibility and varying price points through a combination of three designation levels: Bronze, Silver and Gold. The process begins with Bronze, which includes cost-effective retrofit requirements that must be completed before moving onto the next level to achieve the greatest disaster resistance. The key to FORTIFIED is its thorough inspection process that ensures homeowners are getting the most value for the money they are already spending on home improvements, repairs or rebuilding after a disaster. FORTIFIED Home Standards are also available for new houses.

For more detailed information about how to make your home stronger, safer and more hurricane-resistant, and to download an application, please visit www.DisasterSafety.org/FORTIFIED. Also, follow us on Twitter at @DisasterSafety and on Facebook at www.facebook.com/buildfortified.



Hazard: Hurricane

Locations where the design wind speed exceeds 90 mph as determined in ASCE7-05

Construction Type: New residential, single-family detached homes

FORTIFIED Home™: Hurricane Bronze Requirements:

- Roof deck must be a minimum of 7/16 in. OSB or Plywood.
- Roof deck must be attached with 8d ring shank nails, spaced nominally at 6 in. o.c. along the edges and in the field; unless engineering analysis or local code requires more fasteners at the corners.
- Roof deck must be sealed with a qualified system. There are three qualified methods for sealing from the top side (described below).
 - Cover the entire roof deck with a full layer of self-adhering polymer modified bitumen membrane meeting ASTM D1970 requirements. It is recommended that the membrane is covered with 15# felt before shingles are applied to provide bond break, and to keep shingles from fusing with the self-adhering membrane.
 - Apply a self-adhering polymer modified bitumen flashing tape, which is at least 4 in. wide, directly to the roof deck to seal the horizontal and vertical joints. Next, apply a code-compliant 30-pound ASTM D226, Type II underlayment over the self-adhering tape. This underlayment must be attached using annular ring or deformed shank roofing fasteners with minimum 1 in. diameter caps at 6 in. o.c. spacing along all laps and at 12 in. o.c. in the field, or a more stringent fastener schedule, if required by the manufacturer for high-wind installations. Horizontal laps shall be a minimum of 2 in. and end laps shall be a minimum of 6 in. Nails with plastic or metal caps are allowed in areas where the design wind speed is less than 140 mph. Metal caps are required for areas where the design wind speed is greater than or equal to 140 mph.
 - Apply reinforced synthetic roof underlayment that has an ICC approval as an alternate to ASTM D226 Type II felt paper. The

FORTIFIED HOME™
 Technical Requirements



synthetic underlayment must have minimum tear strength of 20 lbs. per ASTM D1970 or ASTM D4533. This underlayment must be attached using annular ring or deformed shank roofing fasteners with minimum 1 in. diameter caps at 6 in. o.c. spacing along all laps and at 12 in. o.c. in the field, or a more stringent fastener schedule, if required by the manufacturer for high-wind installations. Metal caps are required for areas where the design wind speed is greater than or equal to 140 mph.

- A drip edge must be installed (at eaves and rakes) with 3 in. laps. Drip shall extend ½ in. below sheathing and extend back on the roof a minimum of 2 in. Drip edge at eaves shall be permitted to be installed either over or under the underlayment. Drip edge at gable rake shall be installed over the underlayment. The drip edge shall be mechanically fastened to the roof deck at a maximum of 4 in. o.c.
- Shingle roof covering must be high-wind rated (Class F or higher) based on design wind speed. See chart below:
- Concrete and clay tile systems and their attachment shall meet the requirements of the site design wind speed and exposure category.

ASCE 7-05 Wind Speed (V_{asd})	ASCE 7-10 Wind Speed (V_{ult})	Shingle Wind Testing Standard/Classification
100 MPH	129 MPH	ASTM D3161 (Class F) or ASTM D 7158 (Class G or H) ¹
110 MPH	142 MPH	ASTM D3161 (Class F) or ASTM D 7158 (Class G or H) ¹
120 MPH	155 MPH	ASTM D 7158 (Class G or H) ¹
130 MPH	168 MPH	ASTM D 7158 (Class H) ¹
140 MPH	180 MPH	
150 MPH	H	

¹ **Note:** When used in Exposure D locations, shingles must pass both ASTM D3161 Class F **and** ASTM D7158 Class H testing standard.

FORTIFIED HOME™ Technical Requirements



- Metal panel roof systems and their attachment shall be installed in accordance with the manufacturer's installation instructions and shall provide uplift resistance equal to or greater than the design uplift pressure for the roof based on the site design wind speed and exposure category.
- Gable walls must have minimum of 7/16 in. structural sheathing (OSB or Plywood).
- Gable overhangs must not be vented.
- Gable wall vents must be protected against water intrusion.
- Gable overhangs framed using outlooker framing must have adequate connection at gable wall and at roof framing members. Connection can be determined by structural engineer or by using IBHS prescriptive connection detail (see page 19 of the FORTIFIED Home™: Hurricane Standards, http://disastersafety.org/wp-content/uploads/fortified-hurricane-standards_IBHS.pdf).
- Box type soffit overhangs (eave) and gable overhangs with a depth greater than 12 in. (measured from the back of fascia to exterior wall surface) and covered with aluminum or vinyl material, must have a center brace installed mid-span.
- Roof-mounted vents, including but not limited to ridge vents, off-ridge vents and turbines, must be Florida Building Code TAS 100(A) approved.

Hurricane Silver Requirements:

- All Bronze requirements must be satisfied.
- Gable end walls on gables greater than 48 in. in height must be braced.
- Porches and carports must have adequate connections for uplift pressures based on site design wind speed and exposure category. Connections must be provided from the roof framing to the beam/wall, from beam to column and column to structure below.
- Garage doors must be pressure rated for pressures associated with site design wind speed and exposure category.
 - Exception: if garage door has glazing, door must be pressure rated and impact rated, or pressure rated and protected with a qualified impact-resistant system.

FORTIFIED HOME™ Technical Requirements



- All window, exterior door and skylight openings must be protected with qualified opening protection systems.
 - Qualified opening protection systems must have passed an ASTM E 1996 and E 1886 impact test for large missile "D".

Hurricane Gold Requirements:

- All Bronze and Silver requirements must be satisfied.
- Chimneys must be adequately connected to the roof structure to resist loads based on site design wind speed and exposure category.
- Windows, skylights and glass doors: Windows and glass doors must be rated for the design pressures appropriate for the exposure category, wind speed, window size, and window location on the building. See Appendix C of the FORTIFIED Home™: Hurricane Standards, http://disastersafety.org/wp-content/uploads/fortified-hurricane-standards_IBHS.pdf.
- A continuous load path must be designed and installed providing connection from roof to wall, wall to floor and floor to foundation.
- Walls must have minimum of 7/16 in. structural sheathing (OSB or Plywood).

NOTICE: ALL OF THE ABOVE MUST BE DOCUMENTED PRIOR TO BEING CONCEALED BY FINISHED MATERIALS. TAKE PHOTOGRAPHS OF THE IMPROVEMENTS WHILE THE HOME IS UNDER CONSTRUCTION. A COMPLETE PHOTO FILE SHOULD BE PRESENTED TO THE FORTIFIED EVALUATOR WORKING ON THE PROJECT.

In addition, certification letters from a structural engineer will be required to satisfy the documentation requirements for outlooker framing, gable framing and bracing, porch/carport connections, chimney connections and load path design. Copies of these letters can be obtained from IBHS or your FORTIFIED Evaluator.